



**GAY GROUP OF COMPANIES**  
CONSTRUCTION MANAGEMENT  
GENERAL CONTRACTING

## REQUEST FOR INFORMATION

**PROJECT: Firearms Outlet Canada**

**RFI No. 1**

**JUN-24-2025**

### Questions and Responses

1. Are all concrete block cores filled with grout or just the ones with rebar?
  - a. Refer to wall schedule. Hardened block is 100% filled. Lightweight blocks are filled where rebars are.
2. I couldn't find any specification manual in the plan room. If available, please share it with us, as it would help ensure accurate pricing.
  - a. No specifications. All notes and finishes are noted on drawings.
3. The window schedule elevations indicate that aluminum framing (SW-1 and SW-2) is to be **black anodized**, while the door schedule specifies **clear anodized** finishes for all aluminum doors within these storefronts. Could you please confirm which finish is required—black or clear?
  - a. All aluminum window frames are dark coated.
4. Since the hardware manufacturer and model are not specified, we will be quoting our standard hardware. Is hardware specification available?
  - a. Not specified.
5. In dwg L-L1 parking lot area on east site referring to EV in every spot. I couldn't find any details regarding. Are EV chargers required on each spot? If so, are there any specs regarding? Please advise
  - a. EV chargers are required with parking spaces marked with "EV"



905-623-3234



55 King Street East,  
Bowmanville, ON L1C 1N4



[www.gaygroupco.com](http://www.gaygroupco.com)