


**Electric Consumption (kWh x000)**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	0.07	0.48	1.49	3.69	2.84	0.72	0.11	-	-	9.41
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	9.02	6.75	2.80	0.75	0.03	-	-	-	0.01	0.82	3.52	7.64	31.34
HP Supp.	0.00	0.00	0.00	-	-	-	-	-	-	0.00	0.00	0.00	0.00
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	5.92	5.31	5.73	5.15	5.10	4.85	4.85	5.31	4.39	5.24	5.08	5.53	62.45
Pumps & Aux.	0.07	0.07	0.07	0.06	0.03	0.01	0.00	0.00	0.01	0.05	0.06	0.07	0.51
Ext. Usage	1.52	1.07	1.18	1.14	0.71	0.69	0.71	1.27	1.23	1.27	1.47	1.52	13.75
Misc. Equip.	4.74	4.29	4.94	4.72	4.94	4.72	4.74	5.14	4.32	4.94	4.52	4.53	56.54
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	4.12	3.73	4.29	4.10	4.29	4.10	4.12	4.47	3.76	4.29	3.93	3.95	49.15
Total	25.39	21.21	19.02	15.99	15.57	15.86	18.11	19.03	14.43	16.71	18.58	23.24	223.14

Gas Consumption (Btu x000,000)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	108.49	94.66	74.04	36.57	5.66	-	-	-	0.45	23.09	52.05	90.83	485.85
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	1.55	1.45	1.67	1.57	1.52	1.35	1.26	1.31	1.11	1.32	1.30	1.40	16.84
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	110.05	96.11	75.72	38.14	7.18	1.35	1.26	1.31	1.56	24.41	53.35	92.24	502.69

REPORT- BEPS Building Energy Performance

WEATHER FILE- Toronto ON CWEC

	LIGHTS	TASK LIGHTS	MISC EQUIP	SPACE HEATING	SPACE COOLING	HEAT REJECT	PUMPS & AUX	VENT FANS	REFRIG DISPLAY	HT PUMP SUPPLEM	DOMEST HOT WTR	EXT USAGE	TOTAL
EM1 ELECTRICITY													
MBTU	167.8	0.0	193.0	106.9	32.1	0.0	1.7	213.1	0.0	0.0	0.0	46.9	761.6
FM1 NATURAL-GAS													
MBTU	0.0	0.0	0.0	485.9	0.0	0.0	0.0	0.0	0.0	0.0	16.8	0.0	502.7
	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====
MBTU	167.8	0.0	193.0	592.8	32.1	0.0	1.7	213.1	0.0	0.0	16.8	46.9	1264.2

TOTAL SITE ENERGY 1264.25 MBTU 55.6 KBTU/SQFT-YR GROSS-AREA 55.6 KBTU/SQFT-YR NET-AREA
TOTAL SOURCE ENERGY 2787.37 MBTU 122.7 KBTU/SQFT-YR GROSS-AREA 122.7 KBTU/SQFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.33
PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.00
HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE = 17
HOURS ANY ZONE BELOW HEATING THROTTLING RANGE = 0

NOTE: ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES.

REPORT- ES-E Summary of Utility-Rate:

Custom Elec Rate

WEATHER FILE- Toronto ON CWEC

RESOURCE: ELECTRICITY		DEMAND-INTERVAL 15		3413. BTU/KWH									
BILLING-DAY: 31		RATE-LIMITATION: 0.0000											
METERS: EM1													
POWER-FACTOR: 0.80		EXCESS-KVAR-FRAC: 0.75		EXCESS-KVAR-CHG: 0.0000									
RATE-QUALIFICATIONS		BLOCK-CHARGES				DEMAND-RATCHETS				MIN-MON-RATCHETS			
MIN-ENERGY: 0.0		Cust 1 Elec Energy Blk1											
MAX-ENERGY: 0.0		Cust 1 Elec Demand Blk1											
MIN-DEMAND: 0.0													
MAX-DEMAND: 0.0													
QUALIFY-RATE: ALL YEAR													
USE-MIN-QUAL: NO													
	METERED ENERGY	BILLING ENERGY	METERED DEMAND	BILLING DEMAND	ENERGY CHARGE	DEMAND CHARGE	ENERGY CST ADJ	TAXES	SURCHRG	FIXED CHARGE	MINIMUM CHARGE	VIRTUAL RATE	TOTAL CHARGE
MONTH	KWH	KWH	KW	KW	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)	(\$)	(\$/UNIT)	(\$)
JAN	25391	25391	100.5	100.5	2539	5023	0	0	0	50	0	0.2998	7612
FEB	21212	21212	98.1	98.1	2121	4904	0	0	0	50	0	0.3336	7076
MAR	19017	19017	91.7	91.7	1902	4585	0	0	0	50	0	0.3437	6536
APR	15987	15987	90.4	90.4	1599	4520	0	0	0	50	0	0.3859	6169
MAY	15575	15575	75.1	75.1	1557	3753	0	0	0	50	0	0.3442	5360
JUN	15861	15861	85.1	85.1	1586	4253	0	0	0	50	0	0.3713	5889
JUL	18107	18107	86.4	86.4	1811	4319	0	0	0	50	0	0.3413	6180
AUG	19030	19030	83.3	83.3	1903	4167	0	0	0	50	0	0.3216	6120
SEP	14428	14428	83.2	83.2	1443	4158	0	0	0	50	0	0.3916	5650
OCT	16714	16714	88.7	88.7	1671	4435	0	0	0	50	0	0.3683	6156
NOV	18577	18577	89.2	89.2	1858	4461	0	0	0	50	0	0.3428	6369
DEC	23238	23238	94.7	94.7	2324	4737	0	0	0	50	0	0.3060	7111
	=====	=====	=====		=====	=====	=====	=====	=====	=====		=====	=====
TOTAL	223137	223137	100.5		22314	53313	0	0	0	600		0.3416	76227