



Suite 218  
5468 Dundas St. West  
Islington, Ontario  
M9B 6E3

Tel: (416) 233-1201  
Fax: (416) 233-1202

Principal

**Gino Natale**  
B. Arch. OAA, MRAIC

**PROJECT:** NEW TWO STOREY RESIDENTIAL BUILDING:  
CANNINGTON AFFORDABLE HOUSING FOR SENIORS  
100 McKay Street, Cannington, Ontario

**PROJECT NO:** 16-16

**SUBJECT:** RFI NO: 10

**DATE:** August 20, 2018

---

**Area/Description/Subject:**

Architectural

**Reference Drawings/Specification No:**

Architectural drawings and specification Section 10 31 00 Fireplaces

**Information Requested:**

1. Provide specifications/requirements for the single side corner fireplace unit for Activity Room 238. A two sided model and series number type is noted in the specifications for other rooms.
2. The CGSB has declassified wired glass as an acceptable product for use in screens, doors and side-lites. Is there a specific substitute glass to the specified GWG to be used in this project that will meet current fire rating and impact resistance? Or should GWG be used, but with the understanding that it will not come with any labels or certification, as it will no longer meet current fire/safety requirements?

**Response:**

1. Please reference the manufacturers noted in the specification section to provide a corner model in the same series.
2. Georgian Wire Glass as specified shall be used as this is in conformance with the Ontario Building Code and accepted by Municipalities.

END